

FIRE SAFETY CERTIFICATE

No.179/RFO/FPW/GVMC/2022

Dated:27-06-2025

Certified that the RAVINDRA BHARATHI SCHOOL running under RAVINDRA BHARATHI EDUCATIONAL SOCIETY building at Sy.No.170/8-B, 170/9, 171/6A1, 171/6A2, 171/5-B-2-E Vellanki, Anandapuram, Visakhapatnam comprised of 1 still (s) Ground and 4 (upper floors) owned/occupied by RAVINDRA BHARATHI EDUCATIONAL SOCIETY, have complied with the fire prevention and fire safety requirements in accordance with the rule of A.P.State Fire Service Rules, and verified by the officers concerned of Fire Service on 26-06-2025 in presence of Mr.M.Subrahmanyam, Director and that the building / premises is fit for occupancy up to classes X (X/XII) With effect from 23-04-2022 to 22-04-2027 for a period of 5 years in accordance with rule and subject to compliance of specific conditions as appended.

1. All the protection arrangements shall be maintained in good condition as seen during inspection.
2. All the escape / exit routes shall not be kept locked / blocked or encroached.
3. All the occupants must know the correct method of operation of the firefighting system installed.
4. All students / staff members of the institution shall be trained to operate the fire safety equipment During emergency.
5. Mock drills should be conducted once in 03 months for initial two years. Thereafter, once in every 6 months.

Issued on 27-06-2025 (date of issue) at Visakhapatnam (place) by

Signature with Seal:


Regional Fire Officer
Fire Prevention Wing, GVMC

Name : Y.HANUMANTHA RAO
Designation : Regional Fire Officer
Name & Address of Department / Office:


Fire Prevention Wing, 4th floor, GVMC Zone-IV
office, Beside Venkateswara Theatre,
Suryabagh, Visakhapatnam-530020.

To
RAVINDRA BHARATHI SCHOOL
Running under Ravindra Bharathi Educational Society,
Sy.No.170/8-B, 170/9, 171/6A1, 171/6A2, 171/5-B-2-E
Vellanki, Anandapuram, Visakhapatnam
(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Services stand cancelled an annulled due to non-maintain Fire Safety Measures at all times in good working Condition as seen during the inspection.

(Y.HANUMANTHA RAO, Regional Fire Officer)




HEAD MASTER
RAVINDRA BHARATHI SCHOOL
VELLANKI, ANANDAPURAM(M)
VISAKHAPATNAM